

## Preserving SSC Design Function Using RCM Principles

K. Mohammadi

February 5, 2009

## Disclaimer

This document was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor Lawrence Livermore National Security, LLC, nor any of their employees makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or Lawrence Livermore National Security, LLC. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or Lawrence Livermore National Security, LLC, and shall not be used for advertising or product endorsement purposes.

This work performed under the auspices of the U.S. Department of Energy by Lawrence Livermore National Laboratory under Contract DE-AC52-07NA27344.

## **Preserving SSC Design Function Using RCM Principles**

Kazem Mohammadi
Safety Analysis Engineer
Safety Basis Division
Nuclear Operations Directorate
Lawrence Livermore National Laboratory
P.O. Box 808 (L-372)
Livermore, CA 94551
Phone (925) 423-5795/Fax (925) 423-1787
Mohammadi2@llnl.gov

## Abstract

Reliability-Centered Maintenance (RCM) can be defined as an approach that employs preventive, predictive, proactive, and reactive maintenance practices and strategies in an integrated manner to increase the probability that a Structure, System, or Component (SSC) will function as designed over its life cycle with optimum maintenance. The goal of RCM is to preserve the SSC intended design function at the lowest cost by developing a maintenance strategy that is supported by sound technical and economic justification. RCM has been used extensively by the aircraft, space, defense, power generation, and manufacturing industries where functional failures of SSCs can have the potential to compromise worker or public safety, cause adverse environmental impact, cause loss of production, and/or result in excessive damage to critical SSCs. This paper provides a framework for performing an RCM analysis in support of DOE Order 430.1A (Life Cycle Asset Management) and DOE Order 420.1B (Facility Safety). The influence of RCM on the various aspects of the maintenance program including the work control process is also discussed.